



Northbrook, Illinois • (847) 272-8800
 Melville, New York • (631) 271-6200
 Santa Clara, California • (408) 985-2400
 Research Triangle Park,
 North Carolina • (919) 549-1400
 Camas, Washington • (360) 817-5500

FIKE PROTECTION SYSTEMS, DIV OF
 FIKE CORP
 MR S TITUS
 704 S 10TH ST
 PO BOX 610
 BLUE SPRINGS MO 64013

Your most recent Certification is shown below. You may also view this information, or a portion of this information (depending on the product category), on UL's Online Certifications Directory at www.ul.com/database. Please review the text and contact the Conformity Assessment Services staff member who handled your project if revisions are required. For instructions on placing an order for this information in a 3 x 5-inch format, you may refer to the enclosed order form for UL Card Service.

UOJZ
 Control Units, System

April 24, 2002

FIKE PROTECTION SYSTEMS, DIV OF FIKE CORP
 704 S 10TH ST PO BOX 610, BLUE SPRINGS MO 64013

S2203

| Type | Type Service | Type Signaling | Model |
|-------------------------|-----------------|-------------------|---------------------|
| L+ | A, M, SS | NC | Intella-Scan-II |
| CS*, RS* | A, M, SS | NC | Intella-Scan, Rhino |
| L+ | A, M | NC | Rhino |
| L | A, M, WF, SS | NC | — |
| L | A, M, SS, WF | NC | C10-005 |
| L | A, M, SS | NC | C10-003 |
| P*, CS* | A, M, WF | NC | C10-006 |
| CS*, L+, RS* | A, M, WF, SS | NC | C10-005 |
| CS*, L+, RS* | A, M, WF, SS | NC, M | SHIP |
| A | A, M, WF | NC, M | CHEETAH |
| RS(ppu) | A, M, WF, SS | REV POL | CHEETAH |
| CS(ppu)*, L+, RS*(ppu)* | A, M, WF, SS | NC, M, DACT | Shark |
| | | | Shark |

+Also suitable for releasing device service.

*Requires additional equipment to provide indicated type service.

Type Unit: L - Local; P - Proprietary; CS - Central station.

Type Service: A - Automatic fire alarm; M - Manual fire alarm; WF - Water-flow alarm; SS-Sprinkler supervisory service.

Type Signaling NC: - Non-coded.

LOOK FOR LISTING MARK ON PRODUCT